




**DELHI JAL BOARD: GNCTD  
ZONAL LABORATORY  
WTP WAZIRABAD, DELHI-54**



**TEST REPORT**

Sample ID	Ref. No. D.J.B/DTQC/WZD/2023/Paid-121-122		
Location /Address of Sample	New Delhi Public School, A-Block, Vikash Puri, New Delhi-110018.		
Letter Reference No.	DPS/WT/R/2023	Ref. Letter Date	04.09.2023
Challan No.	258	Challan Date	04.09.2023
Sample Collection date	06.09.2023	Start Date of Analysis	06.09.2023
Any other Information	<b>THE REPORT PERTAINS TO THE PARTICULAR SAMPLE ONLY</b>	End Date of Analysis	09.09.2023
		Reporting Date	11.09.2023

**TEST RESULTS**

S.N.	Parameters	Unit	As per the IS 10500		Results	
			Desirable limit	Permissible limit	Inlet	Outlet
1	Colour	Pt-Co	5	15	2.0	2.0
2	Odour	--	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	1.4	1.5
4	pH Value	--	6.5-8.5	No relaxation	7.34	7.37
5	Electrical Conductivity	µS/cm	-	-	220	224
6	Total Dissolved Solids	mg/L	500	2000	143	146
7	Total Alkalinity	mg/L	200	600	72	74
8	Total Hardness	mg/L	200	600	98	100
9	Calcium as Ca	mg/L	75	200	24	25
10	Magnesium as Mg	mg/L	30	100	9.0	9.0
11	T. Iron	.mg/L	--	1.0	0.06	0.06
12	Chloride	mg/L	250	1000	14	16
13	Fluoride	mg/L	1.0	1.5	0.21	0.23
14	Ammonical-Nitrogen	mg/L	NIL	0.5	BDL	BDL
15	Nitrate	mg/L	--	45	1.7	1.8
16	Sulphate	mg/L	200	400	19.7	21.1
17	Residual Chlorine	mg/L	0.2	1.0	0.30	BDL
18	Coliform Count at 37 °C	MPN/100 ml	Absent	--	0	0

\*BDL=Below Detection Limit

.....End of Report.....

**Remarks: For the tested parameters the above water samples conform IS-10500 & is fit for the drinking purpose.**

*Jay Singh*  
Tested by  
Lab.Tech.


*Asif Kaur*  
Verified by  
Asstt. Chemist

*Prakash*  
Authorized by  
Asstt. Chemist/Water Analyst  
D.J.B. (Govt. of N.C.T. of Delhi)  
Water Works, Wazirabad

*Prakash*  
Principal  
New Delhi Public School  
'A' Block, Vikas Puri  
New Delhi-110018



MUNICIPAL CORPORATION OF DELHI  
PUBLIC HEALTH DEPARTMENT, WEST ZONE  
DR. SAHIB SING VERMA NIGAM BHAWAN  
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2024/D- 3490

Dated: 18/01/24

**HEALTH CERTIFICATE**

1. Name of the School NEW DELHI PUBLIC SCHOOL  
2. School address A-BLOCK, VIKAS PURI, NEW DELHI- 110018  
3. No of shifts 01 (Morning) Timing 07:30 AM TO 2:00 PM  
4. No of students:- Boys 788 Girls 463 Total 1251  
5. No of staff: - Gents 07 Ladies 42 Total 49


**Accommodation provide for classroom as under:-**

- Floor area in the classroom is sufficient /insufficient Sufficient  
Classes are well lighted/ ill lighted Well lighted  
Classrooms are well ventilated/ill ventilated Well ventilated  
Classes are kept/ not kept neat and clean Neat & clean  
Building/ classrooms require/ do not require white wash etc. Not required  
Drinking water is wholesome/ not wholesome Wholesome  
Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

**Note:- Valid for one year from the date of issue**

  
Dy. Health Officer  
West Zone

**Dr. V. N. Bhaget**  
DHO (West Zone)

  
Principal  
New Delhi Public School  
'A' Block, Vikas Puri  
New Delhi-110018